

TEST CERTIFICATE



This Certificate is issued to

Closed-Loop Technology Pte Ltd
Blk 14 Hougang Avenue 7
#01-579
Singapore 538799

FOR

Product: IP 55 Enclosure (For Electronic Equipment and Switchgear, etc)

Brand/Model: Closed-Loop/CPR-WM-2142

Detail: Dimensions : 560x420x1020 (WxDxH)

Specification: IP55 for clauses 13.4(IP5X) and 14.2.5(IPX5) of IEC 60529 : 2001(Category 2 without vacuum pump connected)

Test Report: 55S041512/HPW/THK

Summary

A sample of the product has been tested and is found to comply with the requirements of the above standard.

A handwritten signature in black ink, appearing to read 'Chreytan', written over a horizontal line.

Vice-President
Certification & Inspection

Certificate No:
01338

Date of Original Issue:
02/07/2004

Date of Last Revision:
-

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of PSB Corporation Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Test Certification Scheme.
Note: This Certificate is not a Certificate of Conformity.